



**Marion County Public Works  
Building Inspection Division  
Inspection Checklist**

**Residential Electrical Final**

July 2018

This checklist is intended for our external customers to prepare for an inspection. It is also intended for internal use for our inspectors to improve consistency and overall service delivery.

**Please verify the following before calling for the Inspection:**

**Permits and Plans**

- Job address is posted in a visible location.**
- Permit and approved plans are on site and accessible to the inspector
- Permit information is correct (address, permit number, description of work, etc.).

**General**

- All receptacles for polarity and tamper resistant
- Confirm bubble covers as required for location.
- Confirm GFCI protection as required for location.
- Fixed appliances correctly wired and grounded
- Test AFCI breakers
- Confirm outlets are AFCI protected as required per code
- Confirm bonding if applicable of low voltage systems (security, audio, etcetera)
- Check service receptacles and light for under floor, attic heating
- Check lighting operation overhead lighting switched receptacles
- Check GFCI operation for jetted tubs, and access present for tub motor
- Check closet light fixtures for fully covered bulbs and proper clearance from shelves
- Verify disconnects/breakers lock-outs in place for fixed in place appliances
- Confirm all fixtures over tub/shower appropriate for use
- No receptacles within tub or shower area per code
- Check for proper termination of all unused conductors
- Check GFCI receptacle location in kitchen, countertop, island and peninsula
- Any smoke alarm within 20 feet of a cooking appliance is either a photoelectric type or has an approved silencing means
- Check panel boards for disconnects/beaker identification

**Note: These are general requirements only and do not reflect all conditions. For additional information please contact the Building Inspection Division.**

G:\FORMS\Web\Inspection Check Lists\Residential Electrical Final Checklist.doc