

# SPA

## Public Spa Pool Daily Record Sheet



**Marion County**  
OREGON  
Health & Human Services

<b>Month / Year</b>	<b>Name of Spa:</b>	<b>Location – City</b>
<b>Disinfectant Type:</b>	<b>Unstabilized</b> <input type="checkbox"/> Sodium/Calcium Hypochlorite <input type="checkbox"/> Chlorine Generator <input type="checkbox"/> Bromine <input type="checkbox"/> Chlorine Gas <input type="checkbox"/> Other:	<b>Stabilized</b> (contains Cyanuric Acid) <input type="checkbox"/> Trichlor <input type="checkbox"/> Dichlor
<b>Required Testing Frequency:</b>	<b>Every hour</b>	<b>Every 2 hours</b>

Operator's Initials	DATE	Daily Pre-Opening Tests						Calcium Hardness (1x / wk)	Cyanuric Acid (1x / week)	TDS (Monthly)	Free Cl / Br Readings / pH (every 1 to 2 hrs.)							Number of Bathers - Total	Backwashed – Clean Filters	Recirculation Rate - GPM	Comments –
		Clarity (Yes/No)	SPA Temp (<104°F)	Free Chlorine / Bromine	Combined Cl	pH	Total Alkalinity				Insert the Time the Test is Done (below)										
											Cl / pH	Cl / pH	Cl / pH	Cl / pH	Cl / pH	Cl / pH	Cl / pH				
	1																				
	2																				
	3																				
	4																				
	5																				
	6																				
	7																				
	8																				
	9																				
	10																				
	11																				
	12																				
	13																				
	14																				
	15																				
	16																				
	17																				
	18																				
	19																				
	20																				
	21																				
	22																				
	23																				
	24																				
	25																				
	26																				
	27																				
	28																				
	29																				
	30																				
	31																				

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

	Min.	Ideal	Max.
Free Chlorine	1.5 ppm	3.0 – 5.0 ppm	5.0 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0 - 5.0 ppm	8.0 ppm
pH	7.2	7.3 - 7.5	7.6
Total Alkalinity	80 ppm	90 - 110 ppm	180 ppm
Calcium Hardness	150 ppm	200 ppm	400+
Cyanuric Acid	0	0	150 ppm
Water Temperature	-	102°F	104°F